

Dated:06/07/2020

SHORT QUOTATION NOTICE

Short Quotation Notice in sealed cover affixing Court Fee Stamp of Rs 8.25(Rupees Eight Point Two Five) only is hereby invited from the Registered Govt. Manufacturers/Distributors/Suppliers/Reputed firms/Individuals of Assam for the supply of Fire Extinguishers. The rate quoted should be inclusive of GST and other taxes. The details specifications are enclosed in Annexure-A.

Terms and Conditions-

1. Govt. Court Fee Stamp of Rs 8.25
2. GST Registration Number.
3. PAN Card Number.
4. TAN Number in case of partnership firm, etc.
5. Dealership Certificate.

The intending quotations may be submitted to the office within 13th July, 2020 till 4pm addressing to DDC cum CEO, DDMA, Cachar, DEOC Building, Near Settlement Office, N.M Gupta Road, Silchar, Cachar. Sealed Quotations received will be opened by concerned authority in front of representative from concerned Registered Govt. Manufacturers/Distributors/Suppliers/Reputed firms/Individuals of Assam at 4pm on 13th July,2020 at DDMA, Cachar.

District Development Commissioner cum CEO
District Disaster Management Authority
Cachar, Silchar.

Dated:06/07/2020

Memo No. CRR.39/2014/DDMA/Part-I/106 -A

Copy to:

1. The Superintendent of Police, Cachar
2. DIPRO, for wide publicity through FLS and Print Media.
3. All Concerned for information and necessary action.
4. CA/PA to the Deputy Commissioner, Cachar.

District Development Commissioner cum CEO
District Disaster Management Authority
Cachar, Silchar.

Technical specifications for Fire Extinguishers

Fire Extinguisher (Conforming to IS 15683: 2006)

Item No.	Type of Extinguisher	Capacity
1	CO2 Type Fire Extinguisher fitted with wall bracket/Clamp & fixing screws for wall hanging purpose confirming to IS: 15683:2006 specifications with ISI mark	4.5 Kg
2	ABC Stored pressure Type (Squeeze grip) with high pressure braided discharge hose, plain nozzle and initial charge (Powder) as per IS: 15683:2006 specifications with ISI mark fitted with wall bracket/clamp & fixing screws for wall hanging purpose.	4 Kg

Note:

- i. Each fire extinguisher belonging to **Item No. 1 & Item No.2** shall be supplied with initial charge installed in fire extinguisher and hydraulically tested as per (IS 2190:1992 norms) before delivery and test certificate shall be submitted alongwith supplies.
- ii. IS 2190: 1992 code of practice shall be followed for installation, refilling, general precautions and maintenance of fire extinguishers belonging to **Item No.1 & Item No.2**
- iii. The Construction and performance of the Fire extinguishers belonging to **Item No.1 & Item No.2** should confirm to IS 15683: 2006. Any other not indicated in the specifications, but necessary for satisfactory operation of the supplied equipment, the same shall be included in the offer and to be supplied free of cost even if observed during installation.
- iv. Following details shall be marked on each cylinder as per ISI standards.
 - v.(a). Type of fire and its rating.
 - v.(b). Approval details.
 - v. (c). Year of manufacture and
 - Sl. No. v.(d). Test pressure.
- v. **IS 15683: 2006 Approval certificates must be enclosed alongwith the offer.**
- vi. Manufacturer test certificate and test certificates of test carried out for the items before dispatch.
- vii. Certificate for hydrostatic testing of fire extinguisher supplied.